

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1062:137

Page 1 of 1

CATEGORY: Pull Station/Boxes

LISTEE: Detection Systems, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 223-4060 Fax (585) 421-4263

DESIGN: Models DS9490, DS9490D, MX310, and *MX310D fire alarm pull boxes. Models DS9490 and MX310 are single action while DS9490D and *MX310D are dual action. Refer to the listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm pull boxes for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: Formerly 7300-1062:133

*Rev. 12-22-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

DECEMBER 22, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager